



CITY OF FROSTBURG
PLAN REVIEW REQUIREMENTS
SOLAR PHOTOVOLTAIC
DEVELOPMENT

DEPARTMENT OF COMMUNITY DEVELOPMENT
FROSTBURG MUNICIPAL CENTER
37 BROADWAY, P.O. BOX 440
FROSTBURG, MD 21532

All plans must include the items listed below; plans without the required information will be returned and charged a processing fee. All construction must meet or exceed Maryland Building performance standards. Release of construction documents does not relieve the contractor of this responsibility.

Solar Photovoltaic Development

Unless special permission is granted by the authority having jurisdiction, all commercial plans must be prepared and stamped by a MD Registered Design Professional. Number of inspections to be determined by inspector.

Plans should include all of the following that are applicable:

- Pictures showing how the system will be supported
- Pictures of trusses to make sure they can support the additional weight.
- System must conform to the National Electric Code Section 690 – Solar Voltaic Systems and Article 705 – Interconnected Power Supply Systems.
- All equipment must be listed with the use of photovoltaic systems (i.e. UL or CTL).

IMPORTANT INFORMATION:

- All commercial plans require a professional design and fire marshal review if applicable -